



GRADING PLAN GENERAL NOTES

PUBLIC WORKS DEPARTMENT

1. A GRADING PERMIT FROM THE PUBLIC WORKS DEPARTMENT IS REQUIRED. ALL GRADING SHALL COMPLY WITH THE REQUIREMENTS OF THE CITY OF CORONA GRADING REGULATIONS- CORONA MUNICIPAL CODE 15.36, THESE PLANS, SPECIAL INSTRUCTIONS ON THE PERMIT, AND THE PRELIMINARY GEOTECHNICAL REPORT DATED _____ AND ALL SUBSEQUENT ADDENDUMS.
2. SOURCE OF TOPOGRAPHY IS _____ BY _____ DATED _____.
3. A PRE-GRADING MEETING AT THE SITE IS REQUIRED BETWEEN THE CITY INSPECTOR, THE CIVIL ENGINEER, THE GEOTECHNICAL ENGINEER AND THE GRADING CONTRACTOR. CALL THE DEPARTMENT OF PUBLIC WORKS DEPARTMENT INSPECTION DIVISION AT (951) 279-3511 TO SCHEDULE A PRE-GRADING MEETING AT LEAST 48 HOURS PRIOR TO START OF ANY WORK.
4. HOURS OF OPERATION ARE 7:00 A.M. TO 5:00 P.M. – MONDAY THROUGH FRIDAY EXCLUDING HOLIDAYS.
5. SEPARATE PERMITS SHALL BE REQUIRED FOR ANY IMPROVEMENT WORK IN THE PUBLIC RIGHT-OF-WAY.
6. CONSTRUCTION MATERIAL AND EQUIPMENT SHALL NOT OCCUPY ANY PORTION OF THE PUBLIC RIGHT-OF-WAY, SUCH AS STREET, ALLEY OR PUBLIC SIDEWALK AT ANY TIME. TEMPORARY USE OF PUBLIC RIGHT-OF-WAY, WHENEVER REQUESTED, MUST BE REVIEWED AND APPROVED BY THE PUBLIC WORKS DIRECTOR.
7. REPAIR OR REPLACE ALL EXISTING PUBLIC IMPROVEMENTS DAMAGED OR ALTERED AS REQUIRED BY THE PUBLIC WORKS DIRECTOR.
8. ALL SURVEY MONUMENTS SHALL BE PROTECTED AND PERPETUATED IN PLACE. ANY DISTURBED OR COVERED MONUMENTS SHALL BE RESET BY A QUALIFIED CIVIL ENGINEER OR A LICENSED LAND SURVEYOR.
9. PRIOR TO TAKING WATER FROM A CITY FIRE HYDRANT, THE CONTRACTOR SHALL MAKE ARRANGEMENTS WITH THE PUBLIC WORKS DEPARTMENT TO OBTAIN A FIRE HYDRANT WATER METER. METER LOCATION MAY NOT BE ALTERED WITHOUT DEPARTMENT OF WATER AND POWER APPROVAL.
10. IT SHALL BE THE CONTRACTOR'S RESPONSIBILITY TO VERIFY THE LOCATION OF ALL UTILITIES OR STRUCTURES ABOVE OR BELOW GROUND, SHOWN OR NOT SHOWN ON THESE PLANS. THE CONTRACTOR WILL BE HELD RESPONSIBLE FOR ALL DAMAGE TO ANY UTILITIES OR STRUCTURES CAUSED BY HIS OPERATION.
11. STRICT ADHERENCE TO DUST CONTROL REQUIREMENTS SHALL BE ENFORCED. ADJACENT STREETS ARE TO BE CLEANED DAILY OF ALL DIRT AND DEBRIS RESULTING FROM THIS OPERATION.

12. SEPARATE PERMITS FROM THE BUILDING DIVISION SHALL BE REQUIRED FOR ALL WALLS.
13. AN APPROVED PRECISE GRADING PLAN WILL BE REQUIRED PRIOR TO A BUILDING PERMIT BEING ISSUED.
14. THE DESIGN CIVIL ENGINEER/GEOTECHNICAL ENGINEER/ENGINEERING GEOLOGIST OF RECORD SHALL EXERCISE SUFFICIENT CONTROL DURING GRADING AND CONSTRUCTION TO ENSURE COMPLIANCE WITH THE PLANS, SPECIFICATIONS, AND CODE REQUIREMENTS WITHIN THEIR PURVIEW. THE ENGINEER SHALL SUBMIT "ACKNOWLEDGEMENT CONCERNING EMPLOYMENT" FORM TO THE CITY PRIOR TO THE ISSUANCE OF A GRADING PERMIT.
15. REVISIONS TO THE PLANS ARE TO BE SUBMITTED TO THE PUBLIC WORKS DIRECTOR FOR REVIEW AND APPROVAL PRIOR TO CHANGING ORIGINAL MYLARS.
16. THE CIVIL ENGINEER SHALL SUBMIT WRITTEN CERTIFICATION OF COMPLETION OF ROUGH GRADING IN ACCORDANCE WITH THE APPROVED GRADING PLAN AND CERTIFICATION OF BUILDING PAD ELEVATION PRIOR TO ISSUANCE OF THE BUILDING PERMIT. PAD ELEVATION GRADING TOLERANCE SHALL NOT EXCEED $\pm 0.10'$.
17. AN "AS-BUILT" PRECISE GRADING PLAN SHALL BE SUBMITTED AT THE COMPLETION OF WORK SHOWING ALL WATER QUALITY MANAGEMENT PLAN FACILITIES.
18. GRADING SHALL BE PERFORMED UNDER THE SUPERVISION OF THE GEOTECHNICAL ENGINEER WHO SHALL CERTIFY THAT ALL FILL HAS BEEN PROPERLY PLACED AND SUBMIT A FINAL COMPACTION REPORT FOR ALL FILLS OVER 1' DEEP.
19. THE GEOTECHNICAL ENGINEER SHALL, AFTER CLEARING AND PRIOR TO THE PLACEMENT OF FILL IN CANYONS, INSPECT EACH CANYON FOR AREAS OF ADVERSE STABILITY AND TO DETERMINE THE PRESENCE OR ABSENCE OF SUBSURFACE WATER OR SPRING FLOW. IF NEEDED, DRAINS WILL BE DESIGNED AND CONSTRUCTED PRIOR TO THE PLACEMENT OF FILL IN EACH RESPECTIVE CANYON.
20. FILL AREAS SHALL BE CLEANED OF ALL VEGETATION AND DEBRIS, SCARIFIED TO A MINIMUM DEPTH OF 12 INCHES AND INSPECTED BY THE GEOTECHNICAL ENGINEER PRIOR TO THE PLACING OF FILL.
21. ALL DELETERIOUS MATERIALS, I.E. LUMBER, LOGS, BRUSH, OR ANY OTHER ORGANIC MATERIALS OR RUBBISH SHALL BE REMOVED FROM ALL AREAS TO RECEIVE COMPACTED FILL.
22. UNSUITABLE MATERIALS, SUCH AS TOPSOIL, WEATHERED BEDROCK, ETC., SHALL BE REMOVED AS REQUIRED BY THE GEOTECHNICAL ENGINEER (AND ENGINEERING GEOLOGIST, WHERE EMPLOYED) FROM ALL AREAS TO RECEIVE COMPACTED FILL OR DRAINAGE STRUCTURES.
23. FILLS SHALL BE BENCHED INTO COMPETENT MATERIAL.
24. WHEN CUT PADS ARE BROUGHT TO NEAR GRADE, THE GEOTECHNICAL ENGINEER SHALL DETERMINE IF THE BEDROCK IS EXTENSIVELY FRACTURED OR FAULTED AND WILL READILY TRANSMIT WATER. IF CONSIDERED NECESSARY BY THE GEOTECHNICAL ENGINEER, A COMPACTED FILL BLANKET WILL BE PLACED.
25. WHERE SUPPORT OR BUTTRESSING OF CUT AND NATURAL SLOPES IS DETERMINED TO BE NECESSARY BY THE GEOTECHNICAL ENGINEER, THE GEOTECHNICAL

ENGINEER SHALL SUBMIT DESIGN, LOCATIONS AND CALCULATIONS TO THE PUBLIC WORKS DIRECTOR PRIOR TO CONSTRUCTION. THE GEOTECHNICAL ENGINEER WILL INSPECT AND CONTROL THE CONSTRUCTION OF THE BUTTRESSING AND CERTIFY TO THE STABILITY OF THE SLOPE AND ADJACENT STRUCTURES UPON COMPLETION.

26. ALL CUT SLOPES SHALL BE INVESTIGATED, BOTH DURING AND AFTER GRADING BY THE GEOTECHNICAL ENGINEER, TO DETERMINE IF ANY SLOPE HAS STABILITY PROBLEMS. SHOULD EXCAVATION DISCLOSE ANY GEOLOGICAL HAZARDS, THE GEOTECHNICAL ENGINEER SHALL RECOMMEND NECESSARY TREATMENT TO THE PUBLIC WORKS DIRECTOR FOR APPROVAL. ALL APPROVALS TO BE GRANTED ON THE BASIS OF DETAILED GEOLOGICAL MAPPING AND WRITTEN RECOMMENDATION FROM THE GEOTECHNICAL ENGINEER.
27. MAXIMUM ALLOWABLE CUT AND FILL SLOPES ARE 2 TO 1 OR 30' IN HEIGHT WITHOUT APPROVAL OF THE PUBLIC WORKS DIRECTOR. IF PROPOSED CUT AND FILL SLOPES ARE STEEPER THAN 2:1 OR OVER 30' IN HEIGHT, STABILITY CALCULATIONS WITH A SAFETY FACTOR OF AT LEAST ONE AND FIVE TENTHS (1.5) SHALL BE SUBMITTED BY A GEOTECHNICAL ENGINEER FOR APPROVAL FROM THE PUBLIC WORKS DIRECTOR
28. PROVIDE 4' WIDE BY 1' HIGH BERM OR EQUIVALENT ALONG THE TOP OF ALL FILL SLOPES OVER 5' HIGH, EXCEPT WHERE SHOWN OTHERWISE ON THE PLANS.
29. ALL SLOPES ADJACENT TO PUBLIC RIGHT-OF-WAY SHALL CONFORM TO SECTION 15.36.220 OF THE CORONA MUNICIPAL CODE.
30. ALL SLOPES 4' OR HIGHER SHALL BE PLANTED AND COMPLY WITH REQUIREMENTS OF CHAPTER 17 OF THE CORONA MUNICIPAL CODE.
31. TERRACE DRAINS, INTERCEPTOR DRAINS AND DOWN DRAINS SHALL BE CONSTRUCTED OF 4" PCC (OR GUNITE) REINFORCED WITH 6" X 6" -2 1.4 X 1.4 W.W.M. REBAR SHALL BE GRADE 60 BILLET STEEL CONFORMING TO ASTM A615.
32. ALL CONCRETE STRUCTURES THAT COME IN CONTACT WITH THE ONSITE SOILS SHALL BE CONSTRUCTED WITH TYPE II OR V CEMENT AS DEEMED NECESSARY BY SOLUBLE SULFATE CONTENT TEST CONDUCTED BY THE GEOTECHNICAL ENGINEER. ALL CONCRETE SHALL BE 560-C-3250 (600-E 3250 FOR GUNITE) PER CITY STANDARDS AND SPECIFICATIONS.
33. GROUND SHALL BE PRE-WETTED PRIOR TO THE PLACEMENT OF CONCRETE. MOISTURE LOSS RETARDANT SHALL BE USED WHEN REQUIRED BY THE GEOTECHNICAL ENGINEER OR PUBLIC WORKS DIRECTOR.
34. CITY APPROVAL OF PLANS DOES NOT RELIEVE THE DEVELOPER OF RESPONSIBILITY FOR THE CORRECTION OF ERRORS AND/OR OMISSIONS DISCOVERED DURING CONSTRUCTION. UPON REQUEST, THE REQUIRED PLAN REVISIONS SHALL BE PROMPTLY SUBMITTED TO THE PUBLIC WORKS DIRECTOR FOR APPROVAL.

POST CONSTRUCTION BMP GENERAL NOTES: *(Only Use When WQMP Is Required)*

1. THIS PLAN UTILIZES STRUCTURAL BEST MANAGEMENT PRACTICES (BMPS) FOR POST CONSTRUCTION STORM WATER TREATMENT.

2. CONSTRUCT THE STORM WATER TREATMENT FACILITIES AFTER ALL CONTRIBUTING DRAINAGE AREAS ARE STABILIZED AND TO THE SATISFACTION OF THE ENGINEER OF RECORD.
3. DO NOT USE THE DEVICES AS TEMPORARY SEDIMENT CONTROL FACILITIES DURING CONSTRUCTION.
4. THE FOLLOWING BMPs HAVE BEEN DESIGNED INTO THE PLANS. PLEASE REFER TO THE PROJECT'S APPROVED WATER QUALITY MANAGEMENT PLAN (WQMP) FOR ADDITIONAL BMPs AND OPERATION AND MAINTENANCE DETAILS:

(List All Project's Structural Treatment BMPs)

EROSION CONTROL NOTES

1. EROSION CONTROL IS REQUIRED FOR GRADING OPERATIONS ON A YEAR ROUND BASIS. APPROVED PLANS ARE REQUIRED FOR ALL WORK REQUIRING A GRADING PERMIT.
2. IN CASE OF EMERGENCY, CALL _____ OF _____ (RESPONSIBLE PERSON) _____ (FIRM) AT _____ (24-HOUR PHONE NO).
3. THE ENGINEER OF RECORD WILL SUPERVISE EROSION CONTROL WORK AND ENSURE THAT WORK IS IN ACCORDANCE WITH APPROVED PLANS.
4. CITY APPROVAL OF PLANS DOES NOT RELIEVE THE DEVELOPER FROM RESPONSIBILITY FOR THE CORRECTION OF ERROR AND OMISSION DISCOVERED DURING CONSTRUCTION. UPON REQUEST, THE REQUIRED PLAN REVISIONS SHALL BE PROMPTLY SUBMITTED TO THE PUBLIC WORKS DIRECTOR FOR APPROVAL.
5. THE PUBLIC WORKS DIRECTOR RESERVES THE RIGHT TO MAKE CHANGES OR MODIFICATIONS TO THIS PLAN AS DEEMED NECESSARY.
6. STANDBY CREW FOR EMERGENCY WORK SHALL BE MADE AVAILABLE AT ALL TIMES. NECESSARY MATERIALS SHALL BE AVAILABLE ON SITE AND STOCKPILED AT CONVENIENT LOCATIONS TO FACILITATE RAPID CONSTRUCTION OF TEMPORARY EROSION AND SEDIMENT CONTROL BEST MANAGEMENT PRACTICES (BMPs) OR TO REPAIR ANY DAMAGED BMPs WHEN RAIN IS IMMINENT.
7. AN EFFECTIVE COMBINATION OF EROSION AND SEDIMENT CONTROL BMPs SHALL BE IMPLEMENTED AND MAINTAINED TO PREVENT AND/OR MINIMIZE THE TRANSPORT OF SOIL IN RUNOFF FROM DISTURBED SOIL AREAS ON THE CONSTRUCTION SITE AT ALL TIMES. IN ADDITION, BMPs SHALL BE INSPECTED PRIOR TO PREDICTED STORM EVENTS AND FOLLOWING STORM EVENTS. BMPs SHALL NOT BE MOVED OR MODIFIED WITHOUT THE APPROVAL OF THE CITY INSPECTOR
8. ALL REMOVABLE PROTECTIVE DEVICES SHOWN SHALL BE IN PLACE AT THE END OF EACH WORKING DAY WHEN THE FIVE-DAY RAIN PROBABILITY FORECAST EXCEEDS 40 PERCENT, AS FORECASTED BY THE NATIONAL WEATHER SERVICE.

9. AFTER A RAIN EVENT EXCEEDING ONE-QUARTER INCH IN ANY 12 HOUR PERIOD, OR UPON DIRECTION OF THE PUBLIC WORKS DIRECTOR, ALL SILT AND DEBRIS SHALL BE REMOVED FROM CHECK DAMS, SILT FENCES, AND DESILTING BASINS; AND THE BASINS SHALL BE PUMPED DRY AND RESTORED TO ORIGINAL DESIGN CONDITION. ANY EROSION CONTROL MEASURES DAMAGED DURING A RAIN EVENT SHALL ALSO BE IMMEDIATELY REPAIRED.
10. DESILTING BASINS ARE TO BE CONSTRUCTED AS GRADING OF INDIVIDUAL GRADING AREAS ARE COMPLETE PER ROUGH GRADING PLANS.
11. THE CONTRACTOR SHALL BE RESPONSIBLE AND SHALL TAKE NECESSARY PRECAUTIONS TO PREVENT PUBLIC TRESPASS ONTO AREAS WHERE IMPOUNDED WATER CREATES A HAZARDOUS CONDITION.
12. AREAS SHALL BE MAINTAINED IN SUCH A STATE THAT FIRE ACCESS SHALL BE MAINTAINED AT ALL TIMES (INCLUDING ACCESS TO NEIGHBORING PROPERTIES).
13. GRADED AREAS AROUND THE SITE PERIMETER MUST DRAIN AWAY FROM THE FACE OF SLOPE AT THE CONCLUSION OF EACH WORKING DAY.
14. TEMPORARY EROSION PROTECTION IS REQUIRED FOR MANUFACTURED SLOPES PRIOR TO PERMANENT PLANTING.
15. ALL DISTURBED SLOPES SHALL BE PLANTED AND PROTECTED WITHIN 45 DAYS OF THE COMPLETION OF EACH STAGE OF GRADING. SUITABLE MEASURES TO PREVENT SLOPE EROSION INCLUDING, BUT NOT LIMITED TO, RAPID GROWTH VEGETATION SUFFICIENT TO STABILIZE THE SOIL, SHALL BE INSTALLED ON ALL DISTURBED AREAS UNTIL SUCH TIME AS THE PERMANENT VEGETATIVE COVER SUFFICIENTLY MATURES TO PROVIDE PERMANENT STABILITY.
16. NO OBSTRUCTION OR DISTURBANCE OF NATURAL DRAINAGE COURSES OR EXISTING STORM DRAIN INLETS SHALL OCCUR DURING GRADING OPERATIONS, UNLESS ADEQUATE TEMPORARY/PERMANENT DRAINAGE FACILITIES HAVE BEEN APPROVED AND INSTALLED TO CARRY SURFACE WATER TO THE NEAREST PRACTICAL STREET, STORM DRAIN OR NATURAL WATER COURSE. ALL EXISTING DRAINAGE COURSES ON THE PROJECT SITE MUST BE MAINTAINED IN A STATE TO ALLOW FOR CONTINUOUS FUNCTION.
17. THE CONTRACTOR SHALL CONDUCT HIS OPERATIONS IN SUCH A MANNER THAT STORM RUNOFF WILL BE CONTAINED WITHIN THE PROJECT OR CHANNLED INTO THE STORM DRAIN SYSTEM WHICH SERVES THE RUNOFF AREA. STORM RUNOFF FROM ONE AREA SHALL NOT BE ALLOWED TO DIVERT TO ANOTHER RUNOFF AREA.
18. CONFORMANCE WITH THE REQUIREMENTS OF THESE PLANS SHALL IN NO WAY RELIEVE THE CONTRACTOR FROM HIS RESPONSIBILITIES TO THIS SITE AND ADJACENT PROPERTIES. DURING GRADING OPERATIONS, TEMPORARY DRAINAGE CONTROL SHALL BE PROVIDED TO PREVENT PONDING WATER AND DAMAGE TO ADJACENT PROPERTIES. TEMPORARY DRAINAGE CONTROL SHALL CONSIST OF, BUT NOT BE LIMITED TO, CONSTRUCTING SUCH FACILITIES AND TAKING SUCH MEASURES AS ARE NECESSARY TO PREVENT, CONTROL AND ABATE WATER, MUD AND EROSION DAMAGE TO PUBLIC AND PRIVATE PROPERTY AS A RESULT OF THE CONSTRUCTION OF THIS PROJECT.

19. FILL AREAS WHILE BEING BROUGHT UP TO GRADE AND DURING PERIODS OF COMPLETION PRIOR TO FINAL GRADE, SHALL BE PROTECTED BY VARIOUS MEASURES TO ELIMINATE EROSION AND THE SILTATION OF DOWNSTREAM FACILITIES AND ADJACENT AREAS. THESE MEASURES MAY INCLUDE, BUT SHALL NOT BE LIMITED TO: TEMPORARY DOWN DRAINS, EITHER IN THE FORM OF PIPES OR PAVED DITCHES TO DESILT RUNOFF; PROTECTION SUCH AS SAND BAGS AROUND INLETS WHICH HAVE NOT BEEN BROUGHT UP TO GRADE; AND EARTH BERMS AND APPROPRIATE GRADING TO DIRECT DRAINAGE AWAY FROM THE EDGE OF THE TOP OF SLOPES SHALL BE CONSTRUCTED AND MAINTAINED ON THOSE FILL AREAS WHERE EARTHWORK OPERATIONS ARE NOT IN PROGRESS.
20. CLEARING AND GRUBBING SHOULD BE LIMITED TO AREAS THAT WILL RECEIVE IMMEDIATE GRADING. EROSION CONTROL MEASURES WILL BE REQUIRED TO PROTECT AREAS WHICH HAVE BEEN CLEARED AND GRUBBED PRIOR TO GRADING OPERATION, AND WHICH ARE SUBJECT TO RUNOFF DURING A RAIN EVENT. THESE MEASURES MAY INCLUDE BUT SHALL NOT BE LIMITED TO: GRADED DITCHES; BRUSH BARRIERS AND SILT FENCES. CARE SHALL BE EXERCISED TO PRESERVE VEGETATION BEYOND LIMITS OF GRADING.
21. CONSTRUCTION SITES SHALL BE MANAGED TO MINIMIZE THE EXPOSURE TIME OF DISTURBED SOIL AREAS THROUGH PHASING AND SCHEDULING OF GRADING TO THE EXTENT FEASIBLE AND THE USE OF TEMPORARY AND PERMANENT SOIL STABILIZATION.
22. STOCKPILES OF SOIL SHALL BE PROPERLY CONTAINED TO ELIMINATE OR REDUCE SEDIMENT TRANSPORT FROM THE SITE TO STREETS, DRAINAGE FACILITIES OR ADJACENT PROPERTIES VIA RUNOFF, VEHICLE TRACKING, OR WIND.
23. CONSTRUCTION SITES SHALL BE MAINTAINED IN SUCH A CONDITION THAT WIND OR RUNOFF DOES NOT CARRY WASTES OR POLLUTANTS OFF THE SITE TO STREETS, DRAINAGE FACILITIES OR ADJOINING PROPERTIES.
24. DISCHARGES OTHER THAN STORM WATER (NON-STORM WATER DISCHARGES) ARE PROHIBITED, EXCEPT AS AUTHORIZED BY AN INDIVIDUAL NPDES PERMIT, THE STATEWIDE GENERAL PERMIT FOR STORM WATER DISCHARGES ASSOCIATED WITH CONSTRUCTION ACTIVITY, OR OTHER APPLICABLE GENERAL NPDES PERMIT. POTENTIAL POLLUTANTS INCLUDE BUT ARE NOT LIMITED TO: SOLID OR LIQUID CHEMICAL SPILLS; WASTES FROM PAINTS, STAINS, SEALANTS, SOLVENTS, DETERGENTS, GLUES, LIME, PESTICIDES, HERBICIDES, FERTILIZERS, WOOD PRESERVATIVES, AND ASBESTOS FIBERS, PAINT FLAKES OR STUCCO FRAGMENTS; FUELS, OILS, LUBRICANTS, AND HYDRAULIC, RADIATOR OR BATTERY FLUIDS; CONCRETE AND RELATED CUTTING OR CURING RESIDUES; FLOATABLE WASTES; WASTES FROM STREET CLEANING; SUPER-CHLORINATED POTABLE WATER FROM LINE FLUSHING AND TESTING; AND RUNOFF FROM EQUIPMENT AND VEHICLE WASHING. DURING CONSTRUCTION, DISPOSAL OF SUCH MATERIALS SHOULD OCCUR IN A SPECIFIED AND CONTROLLED TEMPORARY AREA ONSITE PHYSICALLY SEPARATED FROM POTENTIAL STORM WATER RUNOFF, WITH ULTIMATE DISPOSAL IN ACCORDANCE WITH LOCAL, STATE AND FEDERAL REQUIREMENTS.

25. AT THE END OF EACH DAY OF CONSTRUCTION ACTIVITY ALL CONSTRUCTION DEBRIS AND WASTE MATERIALS SHALL BE COLLECTED AND PROPERLY DISPOSED IN TRASH OR RECYCLE BINS.
26. PAVED STREETS, SIDEWALKS AND OTHER IMPROVEMENTS SHALL BE MAINTAINED IN A NEAT AND CLEAN CONDITION, FREE OF LOOSE SOIL, CONSTRUCTION DEBRIS AND TRASH. STREET SWEEPING OR OTHER EQUALLY EFFECTIVE MEANS SHALL BE USED ON A REGULAR BASIS TO CONTROL SILT THAT HAS BEEN DEPOSITED ON STREETS OR SIDEWALKS. WATERING SHALL NOT BE USED TO CLEAN STREETS.
27. DISCHARGING CONTAMINATED GROUNDWATER PRODUCED BY DEWATERING GROUNDWATER THAT HAS INFILTRATED INTO THE CONSTRUCTION SITE IS PROHIBITED. DISCHARGING OF CONTAMINATED SOILS VIA SURFACE EROSION IS ALSO PROHIBITED. DISCHARGING NON-CONTAMINATED GROUNDWATER PRODUCED BY DEWATERING ACTIVITIES MAY REQUIRE A NPDES PERMIT FROM THE SANTA ANA REGIONAL BOARD.
28. ALL CONSTRUCTION CONTRACTOR AND SUBCONTRACTOR PERSONNEL ARE TO BE MADE AWARE OF THE REQUIRED BEST MANAGEMENT PRACTICES AND GOOD HOUSEKEEPING MEASURES FOR THE PROJECT SITE AND ANY ASSOCIATED CONSTRUCTION STAGING AREAS.